

## Route fibers into base

10

(a) Position spool to prepare for routing. (b) Route pigtail and feeder fibers counterclockwise starting along the outer walls and working towards the center of the cassette. (c) Line up the pegs on the cassette base with the mounting holes on the spool to finish routing. (d) Insert spool into base and ensure all fibers are under retaining fingers.











#### Apply Cover 11

(a) Line the tabs on the cover with the slots near the front of the cassette base. (b) Lay the cover flat on the base and ensure all the tabs on the side of the cover and bases are lined up. With one hand holding the cassette base, push cover forward with other hand to engage tabs. Double check the rear tab is also engaged to prevent the cover from sliding off.





# COMMSCOPE

Product Information http://www.commscope.com

29009-B

Product Information http://www.commscope.com/ SupportCenter


COMMSCOPE<sup>®</sup>



TC-96372-IP · Rev B · September, 2023

8 Port Mass Fusion Splice Cassette for

PROPH PRODUCT PAGE **QRCODE** 






Refer to Table 1 for Feeder and Pigtail Lengths. "Feeder Initial Length" is the recommended length of fiber to bring into the cassette. "Feeder Cut Length" and "Pigtail Cut Length" is measured from the front of the cassette and is the recommended cut length for the initial splice. A maximum of (1) rework is allowed per splice.

Feeder Initial Length (in)			Fiber Inside Propel Panel (in)
25	19.5	22.25	21
(63.5 cm)	(49.5 cm)	(56.5 cm)	(53.3 cm)

### Table 1: Pigtail and Feeder Lengths

8 Port Cassette, shown above






2

4










## Install feeder fiber in splice cassette.

(a) Insert plastic sleeve into mesh sleeve and secure using tape. Insert feeder fiber into sleeve.(b) Secure feeder fiber using two cable ties. (c) Snip off ends of cable ties close to head. (d) Push the head downward until it is below the top of the cassette wall.










Extend feeder fibers beyond the front of the cassette base, then measure and trim pigtail and feeder to specified cut length per Table 1.



6 Install splice protectors on all fibers to be spliced Use provided splice protectors. Splice protector length should be 45mm maximum.



Strip, clean, and splice fibers following recommended method.





Locate "P" and "F" marking on spool. When loading splice protectors, ensure pigtail is exiting spool through the side with "P" marking and the feeder is exiting through the side with "F" marking.



## 2 Load splice protectors into splice holder

(a) Load splice protectors into splice holder (b) Utilizing the spool fiber retainers, route pigtail fibers counterclockwise until feeder and pigtail fibers converges.



